




# NEPA MAX GROUND BRASS TR M.H.

INSTALLATION INSTRUCTIONS OF LUMINAIRE NEPA MAX GROUND BRASS TR M.H.


**1 Installation**

Fit the plastic tube into the ground.




**2**

1. Make wiring connections
2. Fit the lighting fixture into the tube



**3 Safety glass replacement/ maintenance**

Lamp replacement



1. Pull lighting fixture out of the tube
2. Release the (4) screws and replace/ clean glass.
3. Replace lamp

## USER INSTRUCTIONS

- The installation of the unit must be done by a qualified electrician.
- The unit must be earthed in case an earth connecting point exists.
- Ensure that the mains is switched off during servicing.
- Do not use bulb(s) bigger than the indicated on units name-plate or packaging.
- Ensure that after the installation, the unit is properly fixed and the cable clamps (if exist) are well tightened.
- Manufacturer will not accept liability for injury or damage resulting from incorrect use or installation
- The unit is not intended to operate in loop connection.
- Wall plugs and terminals are not included.

Surface temperature: 100° C

Surface load: max 5kN

• **CAUTION**  
Replace any cracked shield



Date issued: June 2014